

2022/2022

District Water Testing Laboratory, Jalandhar.

(Deptt. of Water Supply and Sanitation, Jalandhar.)

E-mail: dwtljalandhar@gmail.com

Ref. No. DWTLJAL/054

Dated: 24/6/2022

To


Cambridge International
School Kathar


Subject: Test reports of water samples.

Please find the enclosed herewith the report no. DWTLJAL/054
dated 24/6/2022. You are requested to fill the attached feedback
form and send it District Water Testing Laboratory, Jalandhar.

Samples received on 16/6/2022.

D/A: Test Report


Chairman
Cambridge International School Kathar
V. Koopur, Jalandhar Pin-144106


Quality Manager/ Sr. Chemist
District Water Testing Laboratory,
Jalandhar

**District Water Testing Laboratory,
Water Supply and sanitation Deptt. ,Jalandhar**

ID No. DWTLJA/054

Dated 24/6/2022

**TEST REPORT
Chemical Testing**

Sample Registration No. : DWTLJA/054


Sample code given by customer : Not Applicable

Issued to: - Cambridge International School Kathar

SAMPLE PARTICULARS

Ref. Letter No.	: -
Date of Receipt	: <u>16/6/2022</u>
Sample code given by customer	: <u>N.A</u>
Name / Nature of sample	: <u>water</u>
Condition of the sample	: <u>unsealed</u>
Qty/Pkg	: <u>750</u>
Sampling Method	: <u>Sample not drawn by DWTL Jalandhar</u>
Test Start Date	: <u>16/6/2022</u>
Test Completion Date	: <u>24/6/2022</u>


Chairman
Cambridge International School Kathar
V. Koopur, Jalandhar Pin-144106


Quality Manager/ Sr. Chemist
District Water Testing Laboratory,
Jalandhar

Note:

- ☞ The enclosed results pertain only to the sample tested.
- ☞ The report shall not be used for advertising or any legal purpose without written permission from the Head, DWSS.
- ☞ This report cannot be re-produced, except when in full, without the written permission from the Head, DWSS.
- ☞ The sample shall be destroyed after one month from the date of issue of the report.

ID No. DWTLJAL/054


Dated 24/6/2022


Sample Registration No. : DWTLJAL/054

Sample code given by customer : Not Applicable

Test Results
Chemical Testing


Basic Chemical Parameters (As per IS 10500 : 2012)						
Sr. No.	Parameter	Acceptable limit mg/l	Permissible Limit mg/l	Method Detection Limit (MDL) (mg/l)	Result	Standard / Specification/ Method Followed
1	pH	6.5-8.5	No relaxation			
2	TDS	500	2000	2.0	As per Annexure Attached	IS3025 Part 11
3	Turbidity	1.0	5.0	10		IS3025 Part16
4	Colour	5.0	15.0	0.5		IS3025 Part10
5	Odour	Agreeable	Agreeable	1.0		IS3025 Part4
6	Taste	Agreeable	Agreeable	-		IS3025 Part5
7	Total Hardness	200	600	-		IS3025 Part8
8	Total Alkalinity	200	600	2.0		IS3025 Part21
9	Calcium	75	200	2.0		IS3025 Part23
10	Magnesium	30	100	2.0		IS3025 Part40
11	Chloride	250	1000	2.0		APHA 23 rd Edition 3500-MgB IS3025 Part32
				mg/l: milligram per liter TDS: Total Dissolved Solids		MDL - Method Detection Limit
Note 1:	APHA: American Public Health Association IS: Indian Standard Method			BDL- Below Detection Limit		



Chairman
Cambridge International School Kathar
V. Koopur, Jalandhar Pin-144106


Authorized Signatory

Sr. No.	Registration No.	District	Block	Name of Place	Sample Receipt Date	Source	Depth	Colour	Taste	Odour	PH	TDS	Turbidity	Total Alkalinity	Total Hardness	Calcium	Magnesium	Chloride	
As per IS 3025:2017 : (Requirement Acceptable Limit-Permissible Limit)																			
1	DWTLJAL/0622/C/054	Jalandhar	Adampur	Kathar	24.06.2022	T/WELL	..	4	Agreeable	Agreeable	7.80	300	0.40	274	212	35.27	30.1	32.0	
2	DWTLJAL/0622/C/054	Jalandhar	Adampur	Kathar	24.06.2022	RO	..	2	Agreeable	Agreeable	7.14	164	0.1	138	164	33.66	19.44	20	

Test Result


 Chairman
 Cambridge International School Kathar
 Jalandhar. P.in-144106
 V. J. Koopur, Jalandhar


 Quality Manager
 District Water Testing Laboratory,
 Jalandhar.